



621863P1  
May 6, 2013

Ms. Marcia Gasses  
Town Planner & Land Use Administrator  
Town of Barrington  
PO Box 660  
Barrington NH 03825

SUBJECT: Trinity Conservation LLC, Map 210 Lot 57  
Engineering Review

Dear Ms. Gasses:

As requested, we have completed our review of the revised site plan application for the above referenced project. Our review services were limited to a review of the Sightline Plan/Profile (Sheet 6A) by T.F. Moran (dated April 11, 2013). The following were comments noted during the review.

1. The Green Hill Road profile has been lowered to provide the 300' site distance from the driveway looking north. However, the proposed vertical curve does not provide the 300 foot stopping distance on vehicles approaching from the north. The "k" value of the vertical curve would need to be increased from 10 to 40 to achieve the 300' stopping site distance.

If you should have any questions or comments, please call me.

Very truly yours,  
DuBOIS & KING, INC.

A handwritten signature in black ink, appearing to read 'Jeffrey Adler', is located below the typed name.

Jeffrey A. Adler, P.E.  
Senior Project Manager

JAA/js